

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

RECEIVED

By Juvoni Sterling at 12:00 pm, Jul 14, 2026

TSS RFBI No.: 24
Requestor RFBI No.: 16
Request Date: 7.14.26
From (Bidder): Gustav Keoni dba Precision Construction Services

To: **Juvoni Sterling, Project Director**
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Contact: Ruby Cruz
Phone: (805)458-0756
Fax: N/A
Email: precon@precision.services

Email: Juvoni.Sterling@fire.ca.gov

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEUCO0182
Project Name: Parkfield Fire Station Facility Replacement
Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: N/A Project Manual Reference: N/A

Question:

Please clarify the State Fire Marshal deferred items will also be in requirement of DSA approval. Please provide an anticipated review period for DSA that bidders can include in the preliminary schedule.

State Fire Marshall deferred items do not require DSA approval unless also listed as a DSA deferred item.

Per specification section 013300 Submittal Procedures paragraph 1.6 C.3., "Where review of submittals by the Division of the State Architect or the State Fire Marshall is indicated, allow 12 weeks for initial review and resubmittal review of each submittal."

Response by G. Vincent

Bidder's Authorized Signature: Ruby Cruz

[] Check here if additional pages attached

Page 1 of 1