

# REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

**RECEIVED**

By Juvoni Sterling at 12:01 pm, Jul 14, 2026

To: **Juvoni Sterling, Project Director**  
**Department of Forestry and Fire Protection**  
**Technical Services Section (TSS)**  
**Phone: 916-709-0777**

Email: [Juvoni.Sterling@fire.ca.gov](mailto:Juvoni.Sterling@fire.ca.gov)

TSS RFBI No.: **29**  
Requestor RFBI No.: 21  
Request Date: 7.14.26  
From (Bidder): Gustav Keoni dba Precision  
Construction Services

Contact: Ruby Cruz  
Phone: (805)458-0756  
Fax: N/A  
Email: precon@precision.services

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEU00182  
Project Name: Parkfield Fire Station Facility Replacement  
Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: N/A Project Manual Reference: N/A

## Question:

The PG&E sketch shows PG&E slacking ~64 feet of new overhead primary (P1) from a 50' CL2 interset pole to a 45' CL3 riser pole. PG&E's Environmental Report block on the same sheet designates the site HFTD Tier 2 / State Responsibility Area, and the design is over two years old. Please confirm PG&E has reaffirmed the P1 overhead configuration under its current HFTD standards, with no re-scope anticipated; if not, whether the State will obtain that confirmation by Addendum before bid opening. If PG&E later re-scopes the extension — P1 to underground, added or relocated poles, revised riser — please confirm the cost and time impacts are Change Order work, and state whether the State considers such redesign to fall within Allowance No. 2 (01 21 00, 3.3.B, \$40,000).

## Response:

**No PG&E re-scope is anticipated, at this time. If PG&E re-scopes, a potential change order may be issued.**

**Please bid in accordance with bid documents provided.**

**J. Sterling 7/15/26**

Bidder's Authorized Signature: Ruby Cruz

[ ] Check here if additional pages attached

Page 1 of 1