

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than July 16, 2026, 5:00 p.m.)

RECEIVED

By Juvoni Sterling at 12:40 pm, Jul 16, 2026

TSS RFBI No.: 32
Requestor RFBI No.: 1
Request Date: 7/16/2026
From (Bidder): COAST COUNTRIES GLASS

To: Juvoni Sterling, Project Director
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Contact: CHRIS CORRELL
Phone: (831) 601-6749 (cell)
Fax: (831) 649-4444
Email: Chris@ccgmonterey.com

Email: Juvoni.Sterling@fire.ca.gov

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEUCO0182
Project Name: Parkfield Fire Station Facility Replacement
Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: A601 Project Manual Reference: _____

Question:

Door # 28 IS IDENTIFIED AS A
'FULL VISION w/ SIDELITE'

* PLEASE ADVISE OF THE DESIRED SIZE
FOR THE SIDELITE.

THANK YOU

Door #28 is to have a 2'-0" sidelite. Please note this dimension includes the frame.

Response by S. Hall

Bidder's Authorized Signature: _____

[] Check here if additional pages attached

Page 1 of 1