

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

RECEIVED

By Juvoni Sterling at 6:42 am, Jul 20, 2026

To: **Juvoni Sterling, Project Director**
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Email: Juvoni.Sterling@fire.ca.gov

TSS RFBI No.: **36**
Requestor RFBI No.: **27**
Request Date: **7.16.26**
From (Bidder): **Gustav Keoni dba Precision Construction Services**

Contact: **Ruby Cruz**
Phone: **(805)458-0756**
Fax: **N/A**
Email: **precon@precision.services**

All RFBIs received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: **3540SRAEU00182**
Project Name: **Parkfield Fire Station Facility Replacement**
Location: **70331 Vineyard Canyon Road, Parkfield, California**

SECTION 051200 -
STRUCTURAL STEEL
FRAMING

Drawing Reference: **N/A** Project Manual Reference:

Question:

"Do the ""YES"" and ""NO"" indicators identify drawing sheets that were included in and reviewed by the respective agency (DSA Access Compliance, DSA Structural Safety, and/or OSFM)? **Yes**
Or do the indicators identify drawing sheets that still require future review and approval by the respective agency? **No**
If a sheet is shown as ""NO"" under DSA Structural Safety Review, should bidders interpret that sheet as being excluded from DSA Structural review requirements? **Yes**
Are all sheets included in the Contract Documents fully approved for construction regardless of the review designations shown in the index? **Yes**

Additionally, several drawing sheets, including Sheet CU503, contain the note:

""THIS SHEET IS NOT PART OF THE DSA STRUCTURAL APPROVAL""

Sheet CU503 appears to be a fully engineered and developed construction document; however, the meaning of the above statement is unclear.
Please clarify:

Whether this note indicates that DSA Structural Safety did not review the sheet. **Yes. The content on the drawing is not under the jurisdiction of DSA Structural Safety.**
Whether the Contractor is required to obtain any additional review, approval, delegated design, calculations, or engineering associated with work shown on these sheets. **No**
Whether the work shown on sheets bearing this note may be constructed directly from the Contract Documents without further DSA Structural approval. **Yes**
Whether any portions of the work shown on these sheets will require separate review, deferred approval, or agency acceptance after award. **No**

Contractor's Interpretation

The Contractor understands that the DSA AC Review, DSA SS Review, and OSFM Review columns on Sheet G002 are intended to identify which sheets were submitted to and reviewed by the respective agencies as part of the approval process. The Contractor further assumes that sheets containing the note:

""THIS SHEET IS NOT PART OF THE DSA STRUCTURAL APPROVAL""

have not been reviewed by DSA Structural Safety but remain part of the Contract Documents and may be constructed as shown unless otherwise noted.

Please confirm or clarify this interpretation so that bidders may accurately determine any additional approval, engineering, delegated design, schedule, or cost obligations associated with the work." **Confirmed with the clarification that all drawings were submitted to DSA Structural Safety, but those sheets were only reviewed for confirmation they were not subject to DSA Structural Approval. - Responses by G. Vincent**

Bidder's Authorized Signature: **Ruby Cruz**

[] Check here if additional pages attached

Page 1 of 1