

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

RECEIVED

By Juvoni Sterling at 6:43 am, Jul 20, 2026

TSS RFBI No.: 39
Requestor RFBI No.: 30
Request Date: 7.16.26
From (Bidder): Gustav Keoni dba Precision Construction Services

To: **Juvoni Sterling, Project Director**
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Contact: Ruby Cruz
Phone: (805)458-0756
Fax: N/A
Email: precon@precision.services

Email: Juvoni.Sterling@fire.ca.gov

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEUCO0182
Project Name: Parkfield Fire Station Facility Replacement
Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: N/A Project Manual Reference: SWPP

Question:

Addendum 3 incorporates the SWPPP (Risk Level 2), which names JBD Environmental Consulting as QSD/QSP, while Section 01 57 23 assigns SWPPP compliance to the Contractor. Please confirm which party provides and pays for: QSP site inspections (weekly and storm-event), Risk Level 2 storm-event sampling and laboratory analysis, SMARTS uploads/reporting and any NAL-exceedance reporting, SWPPP amendments, and annual Construction General Permit fees. Please also confirm CAL FIRE remains the Legally Responsible Person and will file the NOT.

Response:

The document provided with addendum #3 is the project FINAL Initial Study/Mitigated Negative Declaration.

For construction, CAL FIRE has engaged the QSP/QSD for project. QSP site inspections, storm-event sampling, laboratory analysis, and SMARTS uploads/reporting are covered and paid for by CAL FIRE and executed by the construction project QSP/QSD and/or assigned.

CAL FIRE is responsible for fees associated with the Construction Stormwater General Permit.

CAL FIRE is identified as the Legally responsible party and will execute the Notice of Termination (NOT).

Prime contractor is responsible for SWPPP Compliance.

Bidder's Authorized Signature: Ruby Cruz

[] Check here if additional pages attached

Page 1 of 1