

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

RECEIVED

By Juvoni Sterling at 6:44 am, Jul 20, 2026

TSS RFBI No.: **43**

Requestor RFBI No.: **34**

Request Date: **7/16/26**

From (Bidder): **Gustav Keoni dba Precision Construction Services**

To: **Juvoni Sterling, Project Director
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777**

Email: Juvoni.Sterling@fire.ca.gov

Contact: **Ruby Cruz**

Phone: **(805)458-0756**

Fax: **N/A**

Email: precon@precision.services

All RFBIs received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: **3540SRAEU00182**

Project Name: **Parkfield Fire Station Facility Replacement**


Location: **70331 Vineyard Canyon Road, Parkfield, California**

Drawing Reference: **N/A** Project Manual Reference: **SWPP**

Question:

Spec Section 101419 requires a professional engineer to design the sign structure and anchorage of the dimensional character sign, assuming this refers to the sign seen in 1/CS502, please clarify if the delegated design is to include the design of all scope seen in this detail (concrete, masonry, steel numbers, anchorage, rebar, etc.) or just the sign which is shown as a faint grey dotted line or is that sign to be OFOI/OFCI?

Delegated-design requirements in Sections 101419 and 101423 are waived and will be removed by future bid addendum. Construct per detail 1/CS502. The sign is to be included in the contract. Detail below will be added by future bid addendum. - Response by G. Vincent



NOTES:

1. TYPOGRAPHIC LETTERING WILL BE PRINTED ON 3M IJ680-10 WHITE SCOTCHLITE REFLECTIVE MATERIAL (OR EQUAL).
2. SIGN SHALL BE IDENTICAL ON BOTH SIDES.

Bidder's Authorized Signature: **Ruby Cruz**

[] Check here if additional pages attached

Page 1 of 1