

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than **July 16, 2026, 5:00 p.m.**)

RECEIVED

By Juvoni Sterling at 9:10 am, Jul 20, 2026

To: Juvoni Sterling, Project Director
Department of Forestry and Fire Protection
Technical Services Section (TSS)
Phone: 916-709-0777

Email: Juvoni.Sterling@fire.ca.gov

TSS RFBI No.: 50
Requestor RFBI No.: 01
Request Date: 07-16-2026
From (Bidder): AMG & Associates Inc

Contact: David Silva
Phone: 661-251-7401
Fax: 661-251-7405
Email: estimating@amgassociatesinc.com

All RFBIs received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 3540SRAEUCO0182
Project Name: Parkfield Fire Station Facility Replacement
Location: 70331 Vineyard Canyon Road, Parkfield, California

Drawing Reference: _____ Project Manual Reference: 133419

Question: Why is spec 133419 metal building system provided? I didn't see any prefabricated buildings on the drawings. Please advise.

The vehicle wash building is a pre-engineered metal building. Please see sheets A101W and S101W for details. Please also see MEP sheets for additional information regarding the vehicle wash building.

Response by S.Hall

Bidder's Authorized Signature: _____

[] Check here if additional pages attached

Page 1 of _____