

Job Location:
 Oak and Stone Development
 2214 LAKE PARK DRIVE
 SAN JACINTO CA 92581

Equipment Plumbing Requirements



DATE 2/2/2026

Job # 626007

Item #	Description	Location	Installed By	QTY	Plumbed By	Water Type	Port Size	GPM	Plumbing Notes	Other Notes
1	40009-V-48-6	All-In-One Pumping Station	Installers	1	Plumber	Fresh	2" Soft Hot		Provide (2) 2" ball valves at stub ups - See cut sheet	
2	E-WT-REJECT-1000-T-A	480 Gallon Reject Water Tank Assembly	Installers	1	Plumber	Fresh	1"		1" Fresh Water Makeup with ball valve	
3	40004-K	Tommy Duplex Water Softener System	Installers	1	Plumber	Fresh	2"	50	Connect preplumbed manifold and softener and drain	
4	E-SE-FLOPRO-24-A-30	Tommy's FloPro	Installers	1	Plumber	Soft HW			Feed AIO PUMP/CITY 1-1/2"/1"	
5	40006-48-6-K	Tommy Water Treatment Center	Installers	1	Plumber	Soft CW/ Hard CW/ RO/ Reclaim	(1) 2" hard water, (1) 1-1/2" soft water, (2) 3" suction		Provide (2) 3" ball valves at reclaim stubs and (1) ball valve at each CW	