



ADDENDUM #6

RFP Due Date 7/10/26

Request for Proposal (RFP)

Sovovatum Village Project – Phase II

Addendum Post Date: **07/6/2026**

Submittal Contact:

John Stacy, Project Manager

Oak and Stone Development

Owners Representative

559 360-2093

john.stacy@oakandstonedevelopment.com



1. Electrical Update

Casino floor (two-story) Power is one circuit per 4 machines. Drawings currently show duplex boxes and should be bid as quads.

2. Carwash Responsibility Matrix

Tommy Carwash Electrical and Plumbing Requirements Matrix (For review in Addendum 6 folder)

3. Updated DU composite added to Exhibit A