Project: City of Santa Paula Police Department Phase II RFB

Address: 214 S. 10th Street, Santa Paula, CA 93060

Date: 11/16/2026

#	Questioner	Question	Response
1	Gabby Wilson, International Vault LLC	Could you please send over the bid documents, or let me know the best way to access them?	The bid documents can be found at bidnetdirect.com.
2	Marc Uy, Woodcliff Corporation	Please advise license requirement and engineers estimate for the project.	A General Contractor's License (Category B) is required for this project.
3	Andrew Nava, FenceCorp	I was reviewing the phase 2 construction drawings and noticed that the fence scope will be on another contract. Can you please provide me that solicitation?	The City of Santa Paula's Police Dept. is not currently soliciting contractors for fencing work. All bid opportunities can be found at bidnetdirect.com.
4	RWC	Scope of Work Clarification	Floor plugs noted on the Flooring Plans (Sheet A2.3) must be included in the Scope of Work. (1) Floor plug in center of Conference Room, (4) floor plugs in the new Briefing/EOC Room. Refer to Furniture Plan (A2.4) for approximate locations.